



DIAGRAM

NOTE TO CUSTOMER:

IN ACCORDANCE WITH PA ACT 287 OF 1974 AS AMENDED, COMMONWEALTH OF PENNSYLVANIA. THE CUSTOMER'S CONSULTING ENGINEERS/ARCHITECTS SHALL FURNISH TO THE INSTALLER THE LOCATION OF ANY UNDERGROUND UTILITIES IN THE VICINITY OF THE PROPOSED ELECTRICAL FACILITIES.

NOTE:

DUQUESNE LIGHT CO. TO HAVE RIGHT OF INGRESS AND EGRESS AT ALL TIMES. DUQUESNE LIGHT CO. TO BE ABSOLVED FROM ALL LIABILITY FOR PROPERTY DAMAGE DUE TO NON-NEGLIGENT INGRESS AND EGRESS OF DUQUESNE LIGHT CO. PERSONNEL OR EQUIPMENT.

NOTE:

TO REQUESTING INSTALLATION OF D.L.CO. EQUIPMENT, AN UNOBSTRUCTED ACCESS WAY CAPABLE OF WITHSTANDING 72,000# TRUCK LOADING MUST BE PROVIDED AND MAINTAINED BY THE CUSTOMER.

NOTE TO TELEPHONE CO.:

BASED ON PRESENT DISTRIBUTION CIRCUIT ARRANGEMENTS, THE PROTECTION SCHEME DOES MEET SPECIFICATIONS SET FORTH IN EEI PUBLICATIONS 68-62.

EQUIPMENT	EQUIPMENT DIMENSIONS	EQUIPMENT CLEARANCE FROM DLCO EQUIPMENT CENTERLINE (FT)			FRONT
		A	B	C	D
TRANSFORMER	6'x6'	4'	4'	4'	9'x6'
FIBERGLASS LOADBREAK BUSHING JUNCTION	10'Lx7'-6"W	6'	6'	6'	9'x6'
FIBERGLASS VAULT	3'x3'	2'-6"	2'-6"	2'-6"	9'x6'
SECONDARY ENCLOSURE	2'Lx1'W	2'	1'-6"	2'	3'x6'

UTILITY EQUIPMENT WORKSPACE CLEARANCE TABLE

(SEE DIAGRAM ABOVE)

*DIMENSIONS INCLUDE GROUND GRID AROUND EQUIPMENT